

# Construction: Glaziers and Painters

## SAFETY CHECKLIST

Name

Department

Date

DESCRIPTION	YES	NO	N/A
Ladders are placed so that the side rails have secure footing.			
Topcap or the step below the topcap of stepladders are not used as steps.			
Ladders are not placed on boxes or other unstable bases to gain height.			
The ladders always extend 3 feet above roof when climbing to the roof of a building and are secured.			
Ladders are not placed in front of a door unless the door is guarded, locked or blocked open.			
Ladders are not placed against a window.			
Employees do not stand or work on the top 3 rungs of straight ladders.			
Proper ladder is used for the job.			
A-frame ladder is not used as a straight ladder.			
Ladders are not placed on scaffold to gain height.			